

Product Code

3132W/7

Check Valve

7/8"-22mm ODS
PS = 50 bar - 725 psi



Product use

Accessories for use with the following ASHRAE 34:2019 refrigerants, Class A1, A2L, or A3:
 HFC (R134A, R32, R404A, R407C, R410A, R507)
 HFO (R1234YF, R1234ZE)
 HFO + HFC (R448A, R449A, R450A, R452A, R452B, R454A, R454B, R454C, R455A, R513A, R515A, R515B)
 HC (R290, R600, R600A, R1270)

Product Details

Connections SAE Flare	-
Connections ODS Ø [in.]	7/8"
ODS Ø [mm]	22
Kv [m³/h]	5
Differential pressure (2) [bar]	0,04
PS [bar]	50
MWP [psi] (1)	725
TS [°C] min.	-40
TS [°C] max.	+150
Package pcs	21

Notes where expressly stated

(1): according to UL approval

(2): minimum pressure at which the valve is completely open